



Winthrop University
Police Department

Daily Fire Log

Month of March, 2023



Incident #: N/A	
Date Reported: 03/01/2023	Time Reported: 10:57 PM
Date(s) Occurred: 03/01/2023	Time(s) Occurred: 10:57 PM
Location: Margaret Nance Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The office responded in reference to a fire alarm and went to check the area. There was no sign of fire or smoke and the alarm was rest.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 03/04/2023	Time Reported: 11:18 AM
Date(s) Occurred: 03/04/2023	Time(s) Occurred: 11:18 AM
Location: E. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 328. There appeared to be heavy steam in the air and the odor of hair fabric. The victim stated she was using a hair dryer and it overheated and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 03/06/2023	Time Reported: 8:13 PM
Date(s) Occurred: 03/06/2023	Time(s) Occurred: 8:13 PM
Location: The Courtyard	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded to conduct a fire drill.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 03/06/2023	Time Reported: 9:10 PM
Date(s) Occurred: 03/06/2023	Time(s) Occurred: 9:10 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded to conduct fire drill.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 03/16/2023	Time Reported: 9:06 PM
Date(s) Occurred: 03/16/2023	Time(s) Occurred: 9:06 PM
Location: The Courtyard	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm on the fourth floor. The officer checked the area and there was no fire or smoke. The alarm was reset.	
Disposition: Complete	



Winthrop University
Police Department

Daily Fire Log

Month of March, 2023



Incident #: N/A	
Date Reported: 03/23/2023	Time Reported: 12:30 PM
Date(s) Occurred: 03/23/2023	Time(s) Occurred: 12:30 PM
Location: The Courtyard	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to the alarm in the 4 th floor service room. Maintenance was being done on the fire hydrant on the ground floor. The alarm will be reset when maintenance was done.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 03/25/2023	Time Reported: 9:14 AM
Date(s) Occurred: 03/25/2023	Time(s) Occurred: 9:14 AM
Location: Roddey Apartments	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm on the 1 st floor. The fire/smoke detector had ants in it. The alarm was rest.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 03/28/2023	Time Reported: 4:50 AM
Date(s) Occurred: 03/28/2023	Time(s) Occurred: 4:50 AM
Location: E. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded to room 310 in reference to a fire alarm being activated. There was no smoke or fire in the room and the alarm was reset.	
Disposition: Complete	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	