



**Winthrop University
Police Department**

Daily Fire Log

Month of September, 2025



Incident #: N/A	
Date Reported: 09/02/2025	Time Reported: 11:24 AM
Date(s) Occurred: 09/02/2025	Time(s) Occurred: 11:24 AM
Location: 601 Oakland Ave.	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to the fire alarm being activated. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/03/2025	Time Reported: 9:05 PM
Date(s) Occurred: 09/03/2025	Time(s) Occurred: 9:05 PM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated on the 1 st floor. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/03/2025	Time Reported: 9:15 PM
Date(s) Occurred: 09/03/2025	Time(s) Occurred: 9:15 PM
Location: Sims Science Building	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no signs of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/04/2025	Time Reported: 1:40 PM
Date(s) Occurred: 09/4/2025	Time(s) Occurred: 1:40 PM
Location: Johnson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to the fire alarm being activated. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/05/2025	Time Reported: 8:08 PM
Date(s) Occurred: 09/05/2025	Time(s) Occurred: 8:08 PM
Location: 2020 Alumni Dr.	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. The elevator had been reported of smelling like smoke. There was a smell but could not determine where it was coming from. The elevator and blocked off and FM was notified.	
Disposition: Complete	



**Winthrop University
Police Department**

Daily Fire Log

Month of September, 2025



Incident #: N/A	
Date Reported: 09/09/2025	Time Reported: 11:15 AM
Date(s) Occurred: 09/09/2025	Time(s) Occurred: 11:15 AM
Location: Conservatory of Music	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. A walk through was completed and there was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/09/2025	Time Reported: 12:26 PM
Date(s) Occurred: 09/09/2025	Time(s) Occurred: 12:26 PM
Location: Conservatory of Music	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to the fire alarm being activated. After two attempts to reset it FM stated they would contact someone from the alarm company to come out.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/11/2025	Time Reported: 1:19 AM
Date(s) Occurred: 09/11/2025	Time(s) Occurred: 1:19 AM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to the fire alarm being activated in room 160. The residents were cooking popcorn in the microwave and using a curling iron which caused the alarm to go off. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/14/2025	Time Reported: 3:30 PM
Date(s) Occurred: 09/14/2025	Time(s) Occurred: 3:30 PM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated in room 260. The resident stated she was blow drying her hair which triggered the alarm. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/16/2025	Time Reported: 5:32 PM
Date(s) Occurred: 09/16/2025	Time(s) Occurred: 5:32 PM
Location: The Courtyard	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated in room 124. The resident stated her smoke detector battery was beeping. A work order was created.	
Disposition: Complete	



**Winthrop University
Police Department**

Daily Fire Log

Month of September, 2025



Incident #: N/A	
Date Reported: 09/17/2025	Time Reported: 10:09 PM
Date(s) Occurred: 09/17/2025	Time(s) Occurred: 10:09 PM
Location: E. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated in room 226. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/24/2025	Time Reported: 4:51 PM
Date(s) Occurred: 09/24/2025	Time(s) Occurred: 4:51 PM
Location: E. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded to room 302 in reference to the smoke detector being activated. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/26/2025	Time Reported: 11:40 AM
Date(s) Occurred: 09/26/2025	Time(s) Occurred: 11:40 AM
Location: The Nest	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/29/2025	Time Reported: 9:41 AM
Date(s) Occurred: 09/29/2025	Time(s) Occurred: 9:41 AM
Location: The Conservatory of Music	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/30/2025	Time Reported: 4:00 PM
Date(s) Occurred: 09/30/2025	Time(s) Occurred: 4:00 PM
Location: Margaret Nance Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a scheduled fire drill. The drill was successfully and the alarm was reset.	
Disposition: Complete	



**Winthrop University
Police Department**

Daily Fire Log

Month of September, 2025



Incident #: N/A	
Date Reported: 09/30/2025	Time Reported: 11:43 PM
Date(s) Occurred: 09/30/2025	Time(s) Occurred: 11:43 PM
Location: Margaret Nance Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated in room 119. The resident was using a blow dryer which caused the alarm to go off. The alarm was reset.	
Disposition: Complete	