



Winthrop University
Police Department

Daily Fire Log

Month of January, 2024



Incident #: N/A	
Date Reported: 01/04/2024	Time Reported: 7:58 AM
Date(s) Occurred: 01/04/2024	Time(s) Occurred: 7:58 AM
Location: Rutledge Building	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. The alarm was going off due to the battery being low.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 01/05/2024	Time Reported: 12:57 PM
Date(s) Occurred: 01/05/2024	Time(s) Occurred: 1:57 PM
Location: W. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. There was an alarm active for the kitchen on the west side from a heat detector. The officer could not reset the alarm and FM was contacted.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 01/10/2024	Time Reported: 11:00 AM
Date(s) Occurred: 01/10/2024	Time(s) Occurred: 11:00 AM
Location: Tillman Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officers responded in reference to a fire alarm. The alarm was caused by steam in the mechanical room.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 01/11/2024	Time Reported: 7:41 PM
Date(s) Occurred: 01/11/2024	Time(s) Occurred: 7:41 PM
Location: Margaret Nance Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 01/12/2024	Time Reported: 1:11 AM
Date(s) Occurred: 01/12/2024	Time(s) Occurred: 1:11 AM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	



**Winthrop University
Police Department**

Daily Fire Log

Month of January, 2024



Incident #: N/A	
Date Reported: 01/14/2024	Time Reported: 3:30 AM
Date(s) Occurred: 01/14/2024	Time(s) Occurred: 3:30 AM
Location: Sims Science Building	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. There was no sign of smoke of fire and the alarm was unable to be reset. FM was contacted to reset the panel.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 01/16/2024	Time Reported: 7:26 PM
Date(s) Occurred: 01/16/2024	Time(s) Occurred: 7:26 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm coming from room 265. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 01/18/2024	Time Reported: 4:15 PM
Date(s) Occurred: 01/18/2024	Time(s) Occurred: 4:15 PM
Location: Rutledge Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was a burnt wire smell and FM was notified and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 01/18/2024	Time Reported: 8:44 PM
Date(s) Occurred: 01/18/2024	Time(s) Occurred: 8:44 PM
Location: E. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to an alarm. The alarm was coming from the 3 rd floor elevator area. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 01/19/2024	Time Reported: 2:22 AM
Date(s) Occurred: 01/19/2024	Time(s) Occurred: 2:22 AM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was smoke coming from room 232 due to there being burned biscuits in the kitchen. RHFD used a fan to clear the smoke and the alarm was reset.	
Disposition: Complete	



Winthrop University
Police Department

Daily Fire Log

Month of January, 2024



Incident #: N/A	
Date Reported: 01/22/2024	Time Reported: 7:35 AM
Date(s) Occurred: 01/22/2024	Time(s) Occurred: 7:35 AM
Location: Rutledge Building	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. FM was also on scene and keyed into one of the mechanical rooms which had steam in it which caused the alarm to sound. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 01/22/2024	Time Reported: 3:19 PM
Date(s) Occurred: 01/22/2024	Time(s) Occurred: 3:19 PM
Location: E. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 01/24/2024	Time Reported: 9:06 PM
Date(s) Occurred: 01/24/2024	Time(s) Occurred: 9:06 PM
Location: W. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded to room 267 in reference to an alarm. The victim stated she had taken a hot shower and that caused the alarm to sound. The alarm was reset.	
Disposition: Complete	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	



Winthrop University
Police Department

Daily Fire Log

Month of February, 2024



Incident #: N/A	
Date Reported: 02/02/2024	Time Reported: 2:10 AM
Date(s) Occurred: 02/02/2024	Time(s) Occurred: 2:10 AM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded to room 210 in reference to a fire alarm being activated. There was no fire or smoke and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 02/02/2024	Time Reported: 7:05 PM
Date(s) Occurred: 02/02/2024	Time(s) Occurred: 7:05 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no sign of smoke or fire and the alarm was set off by a hair straightener. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 02/04/2024	Time Reported: 10:35 PM
Date(s) Occurred: 02/04/2024	Time(s) Occurred: 10:35 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 02/07/2024	Time Reported: 2:07 AM
Date(s) Occurred: 02/07/2024	Time(s) Occurred: 2:07 AM
Location: E. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. The resident advised that steam from the shower set the alarm off. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 02/11/2024	Time Reported: 11:40 PM
Date(s) Occurred: 02/11/2024	Time(s) Occurred: 11:40 PM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated in the 3 rd floor kitchen. The officer observed a pot with vegetable oil in the sink. The alarm was reset.	
Disposition: Complete	



Winthrop University
Police Department



Daily Fire Log

Month of February, 2024

Incident #: N/A	
Date Reported: 02/12/2024	Time Reported: 10:47 PM
Date(s) Occurred: 02/12/2024	Time(s) Occurred: 10:47 PM
Location: W. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded to the 3 rd floor for a fire alarm being activated. There were no signs of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 02/20/2024	Time Reported: 8:41 PM
Date(s) Occurred: 02/20/2024	Time(s) Occurred: 8:41 PM
Location: W. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm, there was no smoke or fire. The officer attempted to reset the alarm but the alarm kept turning back on. The officer contacted the FM contact and they were able to solve the issue.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 02/29/2024	Time Reported: 11:25 PM
Date(s) Occurred: 02/29/2024	Time(s) Occurred: 11:25 PM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded and met with the resident who stated she was spraying Lysol when the smoke detector went off. The alarm was reset.	
Disposition: Complete	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	



Winthrop University
Police Department

Daily Fire Log

Month of March, 2024



Incident #: N/A	
Date Reported: 03/02/2024	Time Reported: 6:20 PM
Date(s) Occurred: 03/02/2024	Time(s) Occurred: 6:20 PM
Location: Withers Building	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to the alarm going off. A walkthrough was conducted and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 03/06/2024	Time Reported: 12:33 AM
Date(s) Occurred: 03/06/2024	Time(s) Occurred: 12:33 AM
Location: The Courtyard	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There officer did a search and there was no smoke or fire.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 03/20/2024	Time Reported: 6:05 AM
Date(s) Occurred: 03/20/2024	Time(s) Occurred: 6:05 AM
Location: Margaret Nance Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no smoke or fire in the study room but there was a smoke smell in the room. Officer observed a broken fan that was causing the smell. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 03/22/2024	Time Reported: 12:35 PM
Date(s) Occurred: 03/22/2024	Time(s) Occurred: 12:35 PM
Location: Rutledge Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There were no signs of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 03/27/2024	Time Reported: 6:30 PM
Date(s) Occurred: 03/27/2024	Time(s) Occurred: 6:30 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. The resident stated she did not know why it activated. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	



**Winthrop University
Police Department**

Daily Fire Log

Month of March, 2024



Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	



**Winthrop University
Police Department**

Daily Fire Log

Month of April, 2024



Incident #: N/A	
Date Reported: 04/09/2024	Time Reported: 9:50 PM
Date(s) Occurred: 04/09/2024	Time(s) Occurred: 9:50 PM
Location: E. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 04/09/2024	Time Reported: 10:03 PM
Date(s) Occurred: 04/09/2024	Time(s) Occurred: 10:03 PM
Location: E. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to an alarm. The resident stated the alarm was due to the steam in the shower. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 04/15/2024	Time Reported: 4:13 PM
Date(s) Occurred: 04/15/2024	Time(s) Occurred: 4:13 PM
Location: McLaurin Hall	
Incident Type: Fire Alarm	
Synopsis: The officer responded in reference to a burning smell odor in the elevator by a third party. The officer did not observe any smoke or fire and no audible alarms were going off.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 04/17/2024	Time Reported: 12:27 PM
Date(s) Occurred: 04/17/2024	Time(s) Occurred: 12:27 PM
Location: Margaret Nance Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. The resident of the room where the alarm was going off was smoking a vape at the time which caused the alarm to sound. The student will be referred to the Dean's office.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 04/18/2024	Time Reported: 7:36 AM
Date(s) Occurred: 04/18/2024	Time(s) Occurred: 7:36 AM
Location: Joynes Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. The complainant stated he went into the room to move some stuff and the alarm went off. The alarm was reset.	
Disposition: Complete	



**Winthrop University
Police Department**



Daily Fire Log

Month of April, 2024

Incident #: N/A	
Date Reported: 04/29/2024	Time Reported: 6:20 PM
Date(s) Occurred: 04/29/2024	Time(s) Occurred: 6:20 PM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a smoke detector going off. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	



Winthrop University
Police Department

Daily Fire Log

Month of May, 2024



Incident #: N/A	
Date Reported: 05/01/2024	Time Reported: 12:47 PM
Date(s) Occurred: 05/01/2024	Time(s) Occurred: 12:47 PM
Location: Thomason Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. Complainant was taking a shower when the smoke detector went off. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 05/05/2024	Time Reported: 11:42 PM
Date(s) Occurred: 05/05/2024	Time(s) Occurred: 11:42 PM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. No one was living in the residence and there was no smoke or fire. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 05/14/2024	Time Reported: 9:47 PM
Date(s) Occurred: 05/14/2024	Time(s) Occurred: 9:47 PM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. There was no sign of fire or smoke. The officer was unable to get the alarm reset and contacted FM to reset it.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 05/28/2024	Time Reported: 11:05 AM
Date(s) Occurred: 05/28/2024	Time(s) Occurred: 11:05 AM
Location: Withers Building	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. The officers canvassed the areas and there was no smoke or fire. The alarm was reset.	
Disposition: Complete	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	



Winthrop University
Police Department

Daily Fire Log

Month of June, 2024



Incident #: N/A	
Date Reported: 06/01/2024	Time Reported: 9:14 AM
Date(s) Occurred: 06/01/2024	Time(s) Occurred: 9:14 AM
Location: Margaret Nance Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 309. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 06/18/2024	Time Reported: 1:20 PM
Date(s) Occurred: 06/18/2024	Time(s) Occurred: 1:20 PM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to the pull station being activated. The pull station was pulled accidentally by the cleaning crew while they were cleaning. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 06/20/2024	Time Reported: 10:52 AM
Date(s) Occurred: 06/20/2024	Time(s) Occurred: 10:52 AM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 69. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	



Winthrop University
Police Department

Daily Fire Log

Month of July, 2024



Incident #: N/A	
Date Reported: 07/03/2024	Time Reported: 8:44 AM
Date(s) Occurred: 07/03/2024	Time(s) Occurred: 8:44 AM
Location: Johnson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. Polk Electric was doing work and turned a fan on in the basement that kicked up dust and caused the alarm to go off.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 07/03/2024	Time Reported: 10:12 AM
Date(s) Occurred: 07/03/2024	Time(s) Occurred: 10:12 AM
Location: Winthrop President's House	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. A paint company was using steam to take wallpaper down which caused the alarm to go off. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 07/05/2024	Time Reported: 12:42 PM
Date(s) Occurred: 07/05/2024	Time(s) Occurred: 12:42 PM
Location: Margaret Nance Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to an alarm in room 338. They were changing out the carpet and there was no smoke or fire. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 07/08/2024	Time Reported: 2:23 PM
Date(s) Occurred: 07/08/2024	Time(s) Occurred: 2:23 PM
Location: Dacus Library	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. A search was completed and there was no smoke or fire. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 07/09/2024	Time Reported: 5:10 PM
Date(s) Occurred: 07/09/2024	Time(s) Occurred: 5:10 PM
Location: Central Energy Plant	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in the boiler room. The alarm was deemed a supervisory alarm from Wofford and Richardson which had no smoke or fire.	
Disposition: Complete	



Winthrop University
Police Department



Daily Fire Log

Month of July, 2024

Incident #: N/A	
Date Reported: 07/26/2024	Time Reported: 2:46 PM
Date(s) Occurred: 07/26/2024	Time(s) Occurred: 2:46 PM
Location: Johnson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. There was a contractor working in the basement using a drill and set the alarm off. The alarm was reset.	
Disposition: Complete	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	



Winthrop University
Police Department

Daily Fire Log

Month of August, 2024



Incident #: N/A	
Date Reported: 08/01/2024	Time Reported: 5:53 AM
Date(s) Occurred: 08/01/2024	Time(s) Occurred: 5:53 AM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference a fire alarm at the 3 rd floor kitchen area. The contractor stated he was cleaning the stove when a burner was left on and while cleaning caused smoke. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 08/08/2024	Time Reported: 10:16 AM
Date(s) Occurred: 08/08/2024	Time(s) Occurred: 10:16 AM
Location: Margaret Nance	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 134. The temperature was high in the room due to the extreme amount of steam coming from the boiler which caused the alarm. FM came to correct the problem.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 08/08/2024	Time Reported: 10:29 AM
Date(s) Occurred: 08/08/2024	Time(s) Occurred: 10:29 AM
Location: Bancroft Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 124. Steam from the boiler caused high temperatures which caused the alarm to sound. FM came to correct the problem.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 08/10/2024	Time Reported: 4:42 PM
Date(s) Occurred: 08/10/2024	Time(s) Occurred: 4:42 PM
Location: Withers Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 322C. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 08/12/2024	Time Reported: 9:20 AM
Date(s) Occurred: 08/12/2024	Time(s) Occurred: 9:20 AM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to two trouble alarms. The officer reset the alarms and suggested that FM come and resolve the issue.	
Disposition: Complete	



Winthrop University
Police Department

Daily Fire Log

Month of August, 2024



Incident #: N/A	
Date Reported: 08/14/2024	Time Reported: 4:44 PM
Date(s) Occurred: 08/14/2024	Time(s) Occurred: 4:44 PM
Location: Rutledge Building	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm at the first floor gallery. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 08/15/2024	Time Reported: 3:48 PM
Date(s) Occurred: 08/15/2024	Time(s) Occurred: 3:48 PM
Location: Rutledge Building	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. The building was searched and there was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 08/17/2024	Time Reported: 4:30 PM
Date(s) Occurred: 08/17/2024	Time(s) Occurred: 4:30 PM
Location: The Courtyard	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded to the Courtyard in reference to a fire alarm. The alarm was showing the 4 th floor and a check of the building found no smoke or fire. FM responded to reset the alarm due to the smoke detector.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 08/19/2024	Time Reported: 1:59 PM
Date(s) Occurred: 08/19/2024	Time(s) Occurred: 1:59 PM
Location: E. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 206. There was no signs of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 08/21/2024	Time Reported: 5:45 AM
Date(s) Occurred: 08/21/2024	Time(s) Occurred: 5:45 AM
Location: Walk2Campus	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm and responded to the room the alarm triggered from. There was no one there and there was no sign of smoke or fire.	
Disposition: Complete	



**Winthrop University
Police Department**

Daily Fire Log

Month of August, 2024



Incident #: N/A	
Date Reported: 08/21/2024	Time Reported: 11:36 PM
Date(s) Occurred: 08/21/2024	Time(s) Occurred: 11:36 PM
Location: Phleps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 224. The officer met with the occupant who stated it just started going off. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 08/25/2024	Time Reported: 11:09 AM
Date(s) Occurred: 08/25/2024	Time(s) Occurred: 11:09 AM
Location: Rutledge Building	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. The officer checked the rooms the alarm was coming from and there was no sign of smoke or fire. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 08/25/2024	Time Reported: 8:37 PM
Date(s) Occurred: 08/25/2024	Time(s) Occurred: 8:37 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to an alarm in room 232. The officer did find food in the shared kitchen. The officer removed the food and turned the oven/stove off.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 08/25/2024	Time Reported: 10:56 PM
Date(s) Occurred: 08/25/2024	Time(s) Occurred: 10:56 PM
Location: Rutledge Building	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded and there were no issues. FM responded to reset the alarm.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 08/26/2024	Time Reported: 11:24 PM
Date(s) Occurred: 08/26/2024	Time(s) Occurred: 11:24 PM
Location: The Courtyard	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in the electric room. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	



**Winthrop University
Police Department**

Daily Fire Log

Month of August, 2024



Incident #: N/A	
Date Reported: 08/31/2024	Time Reported: 12:16 AM
Date(s) Occurred: 08/31/2024	Time(s) Occurred: 12:16 AM
Location: W. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm which was due to the power outage that occurred.	
Disposition: Complete	



**Winthrop University
Police Department**

Daily Fire Log

Month of September, 2024



Incident #: N/A	
Date Reported: 09/06/2024	Time Reported: 11:48 AM
Date(s) Occurred: 09/06/2024	Time(s) Occurred: 11:48 AM
Location: Margaret Nance Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. The resident stated he was spraying Lysol and set the smoke detector off. Alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/07/2024	Time Reported: 2:54 PM
Date(s) Occurred: 09/07/2024	Time(s) Occurred: 2:54 PM
Location: The Courtyard	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to the fire alarm being activated. The officer observed water flow coming from outside room 207. FM will respond to the issue and the alarm was rest.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/11/2024	Time Reported: 10:58 AM
Date(s) Occurred: 09/11/2024	Time(s) Occurred: 10:58 AM
Location: E. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm/heat detector activated in the kitchen area. There were no signs of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/13/2024	Time Reported: 2:47 PM
Date(s) Occurred: 09/13/2024	Time(s) Occurred: 2:47 PM
Location: MacFeat House	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was a employee from IT working on the panel. The panel was reset and secured.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/14/2024	Time Reported: 11:16 PM
Date(s) Occurred: 09/14/2024	Time(s) Occurred: 11:16 PM
Location: W. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated in room 268. The alarm was triggered by the steam from the sower. The alarm was reset.	
Disposition: Complete	



**Winthrop University
Police Department**

Daily Fire Log

Month of September, 2024



Incident #: N/A	
Date Reported: 09/15/2024	Time Reported: 8:00 PM
Date(s) Occurred: 09/15/2024	Time(s) Occurred: 8:00 PM
Location: Macfeat House	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/16/2024	Time Reported: 9:49 PM
Date(s) Occurred: 09/16/2024	Time(s) Occurred: 9:49 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. The victim stated she was cooking noodles when the steam caused the alarm to go off. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/17/2024	Time Reported: 7:07 PM
Date(s) Occurred: 09/17/2024	Time(s) Occurred: 7:07 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 265. The residents stated it randomly went off and there was no signs of smoke or fire. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/17/2024	Time Reported: 10:22 PM
Date(s) Occurred: 09/17/2024	Time(s) Occurred: 10:22 PM
Location: President's House	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded and made contact with the President. There was no signs of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/18/2024	Time Reported: 3:28 AM
Date(s) Occurred: 09/18/2024	Time(s) Occurred: 3:28 AM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 353. There was no sign of smoke or fire. The officer attempted to reset the alarm but was unable to do so. FM was contacted and stated someone would come and fix it.	
Disposition: Complete	



**Winthrop University
Police Department**

Daily Fire Log

Month of September, 2024



Incident #: N/A	
Date Reported: 09/18/2024	Time Reported: 9:09 AM
Date(s) Occurred: 09/18/2024	Time(s) Occurred: 9:09 AM
Location: MacFeat House	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/18/2024	Time Reported: 2:42 PM
Date(s) Occurred: 09/18/2024	Time(s) Occurred: 2:42 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activated	
Synopsis: The officer responded in reference to the fire alarm panel going off due to maintenance cleaning. FM responded to assist in the matter.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/18/2024	Time Reported: 9:51 PM
Date(s) Occurred: 09/18/2024	Time(s) Occurred: 9:51 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activated	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/19/2024	Time Reported: 11:35 AM
Date(s) Occurred: 09/19/2024	Time(s) Occurred: 11:35 AM
Location: Conservatory of Music	
Incident Type: Fire Panel	
Synopsis: The officer responded in reference to the fire panel on the 4 th floor going off. The officer contacted FM to come and assist.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/21/2024	Time Reported: 2:38 PM
Date(s) Occurred: 09/21/2024	Time(s) Occurred: 2:38 PM
Location: Margaret Nance Hall	
Incident Type: Fire Alarm	
Synopsis: The officer responded in reference to a fire alarm coming from room 344. The room was unoccupied at the time and there was no sign of smoke or fire. The alarm was reset.	
Disposition: Complete	



**Winthrop University
Police Department**



Daily Fire Log

Month of September, 2024

Incident #: N/A	
Date Reported: 09/22/2024	Time Reported: 10:44 AM
Date(s) Occurred: 09/22/2024	Time(s) Occurred: 10:44 AM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 360. The resident stated the alarm just randomly started going off. The alarm was disabled and FM was notified.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/22/2024	Time Reported: 8:13 PM
Date(s) Occurred: 09/22/2024	Time(s) Occurred: 8:13 PM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to an alarm in room 360. The occupants stated this was an ongoing problem. FM was notified of the ongoing issue.	
Disposition: Complete	

Incident #: NH/A	
Date Reported: 09/27/2024	Time Reported: 1:37 PM
Date(s) Occurred: 09/27/2024	Time(s) Occurred: 1:37 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activated	
Synopsis: The officer responded in reference to a fire alarm being activated in room 141. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 09/30/2024	Time Reported: 2:59 PM
Date(s) Occurred: 09/30/2024	Time(s) Occurred: 7:59 PM
Location: The Courtyard	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	



Winthrop University
Police Department

Daily Fire Log

Month of October, 2024



Incident #: N/A	
Date Reported: 10/01/2024	Time Reported: 9:05 AM
Date(s) Occurred: 10/01/2024	Time(s) Occurred: 9:05 AM
Location: McLaurin Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 10/02/2024	Time Reported: 8:40 PM
Date(s) Occurred: 10/02/2024	Time(s) Occurred: 8:40 PM
Location: Roddey Apartments	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was a steam pump causing extreme heat. That was turned off and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 10/03/2024	Time Reported: 9:35 AM
Date(s) Occurred: 10/03/2024	Time(s) Occurred: 9:35 AM
Location: McLaurin Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated and a trouble shooting error. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 10/04/2024	Time Reported: 7:20 PM
Date(s) Occurred: 10/04/2024	Time(s) Occurred: 7:20 PM
Location: McBryde Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to sprinkler in the basement bathroom going off and releasing water at a rapid rate. FM was notified as well and assisted in shutting off the water main.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 10/12/2024	Time Reported: 2:20 AM
Date(s) Occurred: 10/12/2024	Time(s) Occurred: 2:20 AM
Location: MacFeat House	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to an alarm. The officer was able to locate a water leak that was pouring from the ceiling. FM was contacted and responded and turned the water valve off.	
Disposition: Complete	



**Winthrop University
Police Department**

Daily Fire Log

Month of October, 2024



Incident #: N/A	
Date Reported: 10/18/2024	Time Reported: 11:57 AM
Date(s) Occurred: 10/18/2024	Time(s) Occurred: 11:57 AM
Location: Tillman Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm. The officer observed water on the floor coming out of the mechanical room and steam in the room. FM was contacted and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 10/21/2024	Time Reported: 3:30 PM
Date(s) Occurred: 10/21/2024	Time(s) Occurred: 3:30 PM
Location: West Center	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. The panel has water damage and the potential to set off again.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 10/21/2024	Time Reported: 5:15 PM
Date(s) Occurred: 10/21/2024	Time(s) Occurred: 5:15 PM
Location: McLaurin Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no smoke or fire and the alarm was reset	
Disposition: Complete	

Incident #: N/A	
Date Reported: 10/22/2024	Time Reported: 11:31 AM
Date(s) Occurred: 10/22/2024	Time(s) Occurred: 11:31 AM
Location: W. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no sign of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 10/25/2024	Time Reported: 2:29 AM
Date(s) Occurred: 10/25/2024	Time(s) Occurred: 2:29 AM
Location: Courtyard at Winthrop Room 305	
Incident Type: Fire Alarm Activation	
Synopsis: The Officer responded in reference to a fire alarm being activated. There was no sign of smoke or fire and the alarm was reset. Work order was placed for the facilities management to check the batteries in the dectector.	
Disposition: Complete	



Winthrop University
Police Department

Daily Fire Log

Month of October, 2024



Incident #: N/A	
Date Reported: 10/30/2024	Time Reported: 3:04 PM
Date(s) Occurred: 10/30/2024	Time(s) Occurred: 3:04 PM
Location: Lee Wicker Hall – Room 345	
Incident Type: Fire Alarm – Smoke Detector	
Synopsis: The officer responded to room 345 at Lee Wicker for the smoke detector beeping, up arrival the officer did not observe and smoke or fire. The alarm was reset without incident.	
Disposition: Complete	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	



**Winthrop University
Police Department**

Daily Fire Log

Month of October, 2024



Incident Type:
Synopsis:
Disposition:



Winthrop University
Police Department

Daily Fire Log

Month of November, 2024



Incident #: N/A	
Date Reported: 11/02/2024	Time Reported: 5:27 PM
Date(s) Occurred: 11/02/2024	Time(s) Occurred: 5:27 PM
Location: Rutledge Basement	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 11/05/2024	Time Reported: 11:55 AM
Date(s) Occurred: 11/05/2024	Time(s) Occurred: 11:55 AM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: 1124-0024	
Date Reported: 11/07/2024	Time Reported: 3:47 PM
Date(s) Occurred: 11/07/2024	Time(s) Occurred: 3:47 PM
Location: McLaurin Hall – 3 rd Floor	
Incident Type: Suspicious Fire	
Synopsis: The officer responded in reference to a fire alarm. The officer went to the 3 rd floor and located a fire inside the janitor closet. There was smoke and fire and RHFD arrived to extinguish the fire. It appears that maybe a surge protector battery cell may have caused the fire.	
Disposition: Admin. Closed	

Incident #: N/A	
Date Reported: 11/07/2024	Time Reported: 9:21 PM
Date(s) Occurred: 11/07/2024	Time(s) Occurred: 9:21 PM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. The officer confirmed there was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 11/13/2024	Time Reported: 1:55 PM
Date(s) Occurred: 11/13/2024	Time(s) Occurred: 1:55PM
Location: Tillman Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated in the elevator mechanical room in the basement. The officer checked the area and found the mechanical room filled with heavy steam. Facilities Management was contacted and responded to the area. The fire alarm was reset without incident.	
Disposition: Complete	



Winthrop University
Police Department

Daily Fire Log

Month of November, 2024



Incident #: N/A	
Date Reported: 11/16/2024	Time Reported: 12:28 PM
Date(s) Occurred: 11/16/2024	Time(s) Occurred: 12:28 PM
Location: E. Thomson Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There were no signs of smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 11/16/2024	Time Reported: 3:21 PM
Date(s) Occurred: 11/16/2024	Time(s) Occurred: 3:21 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 130. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 11/20/2024	Time Reported: 1:45 PM
Date(s) Occurred: 11/20/2024	Time(s) Occurred: 1:45 PM
Location: Lee Wicker Hall – Room 322	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 322. There was no smoke or fire and the alarm was reset without incident.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 11/20/2024	Time Reported: 10:29 PM
Date(s) Occurred: 11/20/2024	Time(s) Occurred: 10:19 PM
Location: Bancroft Hall – Room 157	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm in room 157, elevator equipment room. An outside contractor was working in the room and doing some drilling, which caused some smoke and set the alarm off. The officer conducted a walk-through of the building and did not observe any smoke or fire. The alarm was reset without incident.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 11/22/2024	Time Reported: 2:22 PM
Date(s) Occurred: 11/22/2024	Time(s) Occurred: 2:22 PM
Location: Margaret Nance Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded and met with the subject in her room, she advised she was using her flat iron on her hair and activated the smoke detector. The officer did not observe any signs of fire or smoke and reset the alarm without incident.	
Disposition: Complete	



Winthrop University
Police Department



Daily Fire Log

Month of November, 2024

Incident #: N/A	
Date Reported: 11/24/2024	Time Reported: 7:48 PM
Date(s) Occurred: 11/24/2024	Time(s) Occurred: 7:48 PM
Location: Lee Wicker Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded to a fire alarm activation at room #335, upon arrival and spoke with the occupant who stated her bathroom filled up with steam while showering and set off the alarm. The officer did not observe any signs of smoke or fire, and the alarm was reset without incident.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 11/27/2024	Time Reported: 8:17 AM
Date(s) Occurred: 11/27/2024	Time(s) Occurred: 8:17 AM
Location: McFeat House	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to the fire alarm being activated. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 11/30/2024	Time Reported: 5:22 AM
Date(s) Occurred: 11/30/2024	Time(s) Occurred: 5:22 AM
Location: Rutledge Building	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to the fire alarm being activated. There was no sign of smoke or fire but could not reset the alarm.	
Disposition: Complete	



**Winthrop University
Police Department**

Daily Fire Log

Month of December, 2024



Incident #: N/A	
Date Reported: 12/02/2024	Time Reported: 6:26 AM
Date(s) Occurred: 12/02/2024	Time(s) Occurred: 6:26 AM
Location: MacFeat House	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no sign of smoke or fire and the alarm was reset. FM was also notified.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 12/03/2024	Time Reported: 8:24 AM
Date(s) Occurred: 12/03/2024	Time(s) Occurred: 8:24 AM
Location: MacFeat House	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to the fire alarm being activated. There was no sign of smoke or fire and the alarm was reset. This has been an ongoing issue for the past week and FM was notified	
Disposition: Complete	

Incident #: N/A	
Date Reported: 12/03/2024	Time Reported: 11:50 PM
Date(s) Occurred: 12/03/2024	Time(s) Occurred: 11:50 PM
Location: Lee Wicker	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to the fire alarm being activated. The officer reset the alarm.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 12/04/2024	Time Reported: 8:21 AM
Date(s) Occurred: 12/08/2024	Time(s) Occurred: 8:21 AM
Location: McFeat House	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded regarding an alarm going off near the front door, the alarm was reset and Facilities was contacted because the alarm has been going off every morning.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 12/07/2024	Time Reported: 11:47AM
Date(s) Occurred: 12/07/2024	Time(s) Occurred: 11:47 AM
Location: DiGiorgio Campus Center	
Incident Type: Fire Alarm Activation	
Synopsis: The officer arrived and checked the area; the fire panel was advising a trouble alarm for the roof top duct detector. The officer did not observe and smoke or fire but had the on-call Facilities Management person contacted to check the area.	
Disposition: Complete	



Winthrop University
Police Department

Daily Fire Log

Month of December, 2024



Incident #: N/A	
Date Reported: 12/10/2024	Time Reported: 2:29 PM
Date(s) Occurred: 12/10/2024	Time(s) Occurred: 2:29 PM
Location: DiGiorgio Campus Center	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. There was no smoke or fire and the alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 12/16/2024	Time Reported: 12:56 PM
Date(s) Occurred: 12/16/2024	Time(s) Occurred: 12:56 PM
Location: Bancroft Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded in reference to a fire alarm being activated. The panel advised water flow problem. The building was checked and no leak was visibly. The alarm was reset.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 12/22/2024	Time Reported: 9:39 AM
Date(s) Occurred: 12/22/2024	Time(s) Occurred: 9:39 AM
Location: Phelps Hall	
Incident Type: Fire Alarm Activation – Fire/Trouble Alarm	
Synopsis: The officer received a fire alarm activation at the Winthrop Police Department. The officer responded to the area and the fire panel was advising that the smoke detectors in rooms 120 and 382 were excessively dirty. The officer was able to silence the alarm and checked the building and found no other issues.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 12/22/2024	Time Reported: 12:39 PM
Date(s) Occurred: 12/22/2024	Time(s) Occurred: 12:39 PM
Location: Sims Science Building	
Incident Type: Fire Alarm Activation – Fire/Trouble Alarm	
Synopsis: The officer received a trouble alarm through the fire alarm computer at Winthrop Police Department. The officer arrived and checked the panel, which was advising there was a card issue. The officer checked the building and did not locate any issues.	
Disposition: Complete	

Incident #: N/A	
Date Reported: 12/26/2024	Time Reported: 2:55 AM
Date(s) Occurred: 12/26/2024	Time(s) Occurred: 2:55 AM
Location: DiGiorgio Campus Center	
Incident Type: Fire Alarm – Trouble Alarm Activation	
Synopsis: The officer responded to the area in reference to an alarm activation, the officer checked the building and did not locate any smoke or fire. Once at the panel, it was discovered this was a trouble alarm and a work order was submitted.	
Disposition: Complete	



Winthrop University
Police Department



Daily Fire Log

Month of December, 2024

Incident #: N/A	
Date Reported: 12/31/2024	Time Reported: 12:37 PM
Date(s) Occurred: 12/31/2024	Time(s) Occurred: 12:37 PM
Location: Margaret Nance Hall	
Incident Type: Fire Alarm Activation	
Synopsis: The officer responded to a fire alarm for room 203 at Margaret Nance. Once on scene, the officer checked the area and did not observe any smoke or fire. The alarm was reset without incident.	
Disposition: Complete	

Incident #:	
Date Reported:	Time Reported:
Date(s) Occurred:	Time(s) Occurred:
Location:	
Incident Type:	
Synopsis:	
Disposition:	