

REQUEST FOR QUOTATION

October 5, 2023

RFQ: FY24-Gamewell Alarm System Digitizer

REPLY BY: October 9, 2023 @ 9:00 am

REPLY TO: Anna Marie PHONE NUMBER: 803-323-2143

Senor Procurement Officer EMAIL: triestera@winthrop.edu

DELIVERY DESTINATION: INVOICE TO:

Winthrop University Winthrop University
Rock Hill SC 290733 Accounts Payable

125 Tillman Bldg. Rock Hill SC 29733

PAYMENT TERMS: NET 30

SCOPE OF WORK:

Furnish, install and program a Digitize 3505 Prism LX (or approved equal that will perform the same functions) with a printer to connect the campus Gamewell master box loop alarm system into a computerized output

Specifications:

- 1. Furnish all labor and material as needed per these specifications to include the installation, set up programming and operations of a new alarm system.
- 2. One Digitize 3505 prims lx with USB keyboard. Easy loading, 3 1/8 inch, Graphic Thermal Logging Printer. Alarm text messages logged on printer 5.7 Color LCD with LED backlighting, One (1) GHz Dual-Core ARM Cortex-A7 Processor. New updated fully regulated power supply PN 400596-0001. Meets European IEC 61000-3-2 standard for harmonic content at the input. Program updates and User Text may be uploaded/backed up in a few seconds using your web browser and the built-in Ethernet port of the Prism LXtm, even while the system continues to monitor alarms. Utilizes the Linux Operating System running C Language Alarm Monitoring Program. 50 times faster than the System 3505 CPU-7 Provides a full complement of user memory in excess of 30,000 text messages (48 characters per text message). Enhanced Alarm LAN capability Capable of immediate factory support to assist in configuration and system analysis via cell phone tether. CPU-8 provides dedicated Ethernet, RS-232 and 2 USB ports.

- 3. One TCI-1, 1 CKT TELEGRAPH DECODE, 100MA/24V Consists of AIC-4 card and software (Single circuit telegraph decode, user selectable 24V, 100Ma or Dry contact input).
- 4. SEBB-6/24, SUPERVISED 24 Volt Charger W/ LCD DISPLAY with Batteries.
- 5. SYSTEM 3505/PRISM LX ANNUAL SOFTWARE MAINTENANCE& PHONE SUPPORT AGREEMENT for the 1st year. Future years software and maintenance to be paid on a separate PO/agreement
- 6. Installation of system to include programming of new system to identify the existing Gamewell master box signals into an electron ic output/alarm
- 7. Digitizer to be installer in the Campus Police dispatch office in the Good Building, 526 Myrtle Drive
- 8. Contractor to be experienced with Gamewell master box alarm systems and converting their signals into an electrical/digitized output that can be read/interpreted by a computerized monitoring system.
- 9. Must be a licensed fire alarm contractor in the state of South Carolina

BIDDING SCHEDULE:

Item	em Quantity Unit of Measure			Description		Unit Price		Total	
1	1	LOT	Furnish, install, and program a Digitized 3505 Prisim LX (or equal that will provide same functions) with printer to connect the campus Gamewell master box loop alarm system into a computerized output **Must bid as specified** ***If offering equal, you MUST provide descriptive literature***			\$		\$	
	(Question		Mandatory / Optional	Multiple Responses Accepted?	Response			
Vendo Procur 1524(C this so a FAQ	r Preference ement Code C)(1)(I)&(II) licitation for on these pr	g the SC Res ?? See the SC , Section 11:) and Section r more information of the section of the	-35- a IIB of mation. For ease see	Mandatory	No	Yes No			
SC End-Product Pref. Section 11-35- 1524 (B)(2). Select SC End Product Preference if product is made, manufactured or grown in SC. Select No, if not claiming a preference.				Mandatory	No	Yes No			
1524, o produc	(B)(1). Select is made, notice that the select No. Select No.	ref. Section et US End Pr nanufactured Vo, if not cla	oduct if or grown	Mandatory	No	Yes No			
			GRANE	O TOTAL					
Vendor Name:						Date:			
Name o	of Person Su	bmitting Of	fer:			-			
Signatu	re:					_			

Email Address: ______ Phone Number: _____